

Test laboratory for the fire behavior of building materials, Dipl.-Ing. (FH) Andreas Hoch  
Testing, supervising and certifying body, authorized by the building supervision authority

# TEST REPORT

## PB-Hoch-161296

**for the proof of Fire behaviour according to DIN 4102, part 1**  
**Translation of the German test report – no guarantee for translation of technical terms**  
**external surveillance of the production by “SKZ” (II/2016)**  
**SKZ no: 6282 & 6283 / Cert. no: SKZ A 7061**

<b>company</b>	<b>NICOLL POLSKA Sp. z.o.o.</b> Ul. Energetyczna 6 56-400 Olesnica – Poland
<b>production plant</b>	<b>NICOLL POLSKA Sp. z.o.o.</b> Ul. Energetyczna 6 56-400 Olesnica – Poland
<b>description of samples</b>	waste water pipe, consisting of PP-HT
<b>name of the material</b>	„Tipplen H 880“ / „Tipplen K 850“
<b>sampling</b>	by “SKZ” in the production plant (external surveillance)
<b>content of request</b>	Proof of flammability to classify building materials to class B1 “schwerentflammbar” according to DIN 4102, part 1
<b>date of visit in the production plant</b>	13.10.2016
<b>result</b>	<b>The examined product meets the requirements of class B1 for “schwerentflammbare” (hardly flammable) building materials according to DIN 4102, part 1 (May 1998).</b> <b>The product shows burning droplets.</b>

This test report includes 3 pages and 2 enclosures.

Remark: If the above mentioned building material is not used as product according to MBO § 2, Abs. 9, Ziffer1, there is no need for a general building supervisory test report.

This test report is not valid if the examined building material is used as product in the meaning of state building prescriptions (MBO § 17, Abs. 3).

This test report does not replace an eventually necessary proof of applicability concerning building supervisory or building laws in the meaning of state building prescriptions. This has to be verified by:

- “allgemeine bauaufsichtliche Zulassung” (general building inspectorate approval ) or by
- „allgemeines bauaufsichtliches Prüfzeugnis” (general building inspectorate certificate) or by
- “Zustimmung im Einzelfall” (exceptional approval)

This test report can underlie building supervisory procedures

- for regular building products for the prescribed proofs of conformity
- for non regular building products for the needed proofs of applicability.

This test report must not be published and copied without preceding agreement of the test laboratory and if agreed, only during validity and unchanged concerning appearance and contents.